



Shire Controls Ltd

SA-6 1 GAS AREA ALARM

Drawing No SA1G

Date 05-02-99

Issue 1

NOTE

ALL SIGNAL CABLE TO BE A MINIMUM
OF 0.5 mm sq SCREENED / S.W.A /
OR IN METAL CONDUIT.

ALL JUNCTION BOXES MUST HAVE
THE SCREENS CONNECTED THROUGH